


# Certificate of Compliance

*Awarded to:*

Colder Products Company  
2820 Cleveland Avenue  
Roseville, MN 55113

*The following rooms MET the requirements of ISO 14644-1:2015  
at 0.5 and 5.0 micron in the operational mode on*

05 OCT 2021



Room Name	ISO Class
Production Room	ISO Class 7
Gowning	ISO Class 7
Transfer In	ISO Class 7
Transfer Out	ISO Class 7



**Mike Turnure**  
Pace Analytical Services, LLC  
Cleanroom Qualification Program Manager  
LabOps Instrument Support Group (ISG)


# Certificate of Compliance

*Awarded to:*

Colder Products Company  
2820 Cleveland Avenue  
Roseville, MN 55113

*The following rooms MET the requirements of ISO 14644-1:2015  
at 0.5 and 5.0 micron in the operational mode on*

04 OCT 2021



Room Name	ISO Class
Cleanroom Expansion	ISO Class 7
Temporary Pass Through	ISO Class 7
Temporary Gown Room	ISO Class 7



**Mike Turnure**  
Pace Analytical Services, LLC  
Cleanroom Qualification Program Manager  
LabOps Instrument Support Group (ISG)


# Certificate of Compliance

*Awarded to:*

Colder Products Company  
2820 Cleveland Avenue  
Roseville, MN 55113

*The following rooms MET the requirements of ISO 14644-1:2015  
at 0.5 and 5.0 micron in the operational mode on*

01 OCT 2021



Room Name	ISO Class
Production Main	ISO Class 7
Gowning	ISO Class 7
Transfer In	ISO Class 7
Transfer Out	ISO Class 7



**Mike Turnure**  
Pace Analytical Services, LLC  
Cleanroom Qualification Program Manager  
LabOps Instrument Support Group (ISG)