

# Certificate of Compliance

*Awarded to:*

Colder Products Company  
2820 Cleveland Avenue  
Roseville, MN 55113

*The following rooms MET the requirements of ISO 14644-1:2015  
at 0.5 and 5.0 micron in the Operational mode on*

11 AUG 2022 / 15 SEP 2022

Room Name	ISO Class
Production Room	ISO Class 7
Gowning	ISO Class 7
Transfer In	ISO Class 7
Transfer Out	ISO Class 7
Temp Gowning	ISO Class 7
Temp Pass Through	ISO Class 7



**Daniel Takata**  
Pace Analytical Services, LLC  
Field Service Manager  
Technical Field Services (TFS)