

Certificate of Compliance

Awarded to:

Colder Products Company
2820 Cleveland Avenue
Roseville, MN 55113

*The following rooms MET the requirements of ISO 14644-1:2015
at 0.5 and 5.0 micron in the operational mode on*

30 JUN 2020

Room Name	ISO Class
Production Main	ISO Class 7
Gowning	ISO Class 7
Transfer-In	ISO Class 7*
Transfer-Out	ISO Class 7

*Certified on 28 Jul 2020



Mike Turnure
Pace Analytical Services, LLC
Cleanroom Qualification Program Manager
LabOps Instrument Support Group (ISG)